

Impacts of Data Quality on Real-Time Locational Marginal Price: A Worst Case Analysis

Liyan Jia, Jinsub Kim, Robert J. Thomas, *Life Fellow, IEEE*, and Lang Tong, *Fellow, IEEE*

Abstract—The problem of characterizing impacts of worst data on real-time locational marginal price (LMP) is considered. Because the real-time LMP is computed from the estimated network topology and system state, bad data that cause errors in topology processing and state estimation affect real-time LMP. It is shown that the power system state space is partitioned into price regions of convex polytopes. Under different bad data models, the worst case impacts of bad data on real-time LMP is analyzed. Numerical simulations are used to illustrate worst case performance for IEEE-14 and IEEE-118 networks.

Keywords—locational marginal price (LMP), real-time market, power system state estimation, bad data detection, cyber security of smart grid.

I. INTRODUCTION

THE deregulated electricity market has two interconnected components. The day-ahead market determines the locational marginal price (LMP) based on the dual variables of the optimal power flow (OPF) solution [1], given generator offers, demand forecast, system topology, and security constraints. The calculation of LMP in the day-ahead market does not depend on the actual system operation. In the real-time market, on the other hand, an ex-post formulation is often used (*e.g.*, by PJM and ISO-New England [2]) to calculate the real-time LMP by solving an incremental OPF problem. The LMPs in the day-ahead and the real-time markets are combined in the final clearing and settlement processes.

The real-time LMP is a function of data collected by the supervisory control and data acquisition (SCADA) system. Therefore, anomalies in data, if undetected, will affect prices in the real-time market. While the control center employs a bad data detector to “clean” the real-time measurements, miss detections and false alarms will occur inevitably. The increasing reliance on the cyber system also comes with the risk that malicious data may be injected by an adversary to affect system and real-time market operations. An intelligent adversary can carefully design a data attack to avoid detection by the bad data detector.

Regardless the source of data errors, it is of significant value to assess potential impacts of data quality on the real-time market, especially when a smart grid may in the future deploy demand response based on real-time LMP. To this end, we are interested in characterizing the impact of *worst case data*

errors on the real-time LMP. The focus on the worst case also reflects the lack of an accurate model of bad data and our desire to include the possibility of data attacks.

A. Summary of Results, Contexts, and Approaches

We aim to characterize the effects of the worst data on real-time LMP. The complete characterization of worst data impact is not computationally tractable. Our goal here is to develop an optimization based approach to search for worst data and evaluate the effects of worst data by simulations. In characterizing the relation between data and real-time LMP, we first present a geometric characterization of the real-time LMP.

In particular, we show that the state space of the power system is partitioned into polytope price regions, as illustrated in Fig. 1, where each polytope is associated with a unique real-time LMP vector, and the price region $\mathcal{X}_i$ is defined by a particular set of congested lines that determine the boundaries of the price region.




Fig. 1: Geometric characterization of LMP

Two types of bad data are considered in this paper. One is the bad data associated with meter measurements such as the branch power flows in the network. Such bad data will cause errors in state estimation, possibly perturbing, as an example, the correct state estimate $\hat{x}$ in $\mathcal{X}_0$ to $\tilde{x}$ in $\mathcal{X}_3$ (as shown in Fig. 2(a)). The analysis of the worst case data then corresponds to finding the worst measurement error such that it perturbs the correct state estimation to the worst price region.

The second type of bad data, one that has not been carefully studied in the context of LMP in the literature, is error in digital measurements such as switch or breaker states. Such errors lead directly to topology errors therefore causing a change in the polytope structure as illustrated in Fig. 2(b). In this case, even if the estimated system state changes little,

L. Jia, J. Kim, R. J. Thomas, and L. Tong are with the School of Electrical and Computer Engineering, Cornell University, Ithaca, NY 14853, USA. Email: {lj92, jk752, rjt1, ltong}@cornell.edu. Part of this work was presented at HICSS 2012 and PES General Meeting 2012.

This work is supported in part by a grant under the DoE CERTS program, the NSF under Grant CNS-1135844, and a PSERC grant.




Fig. 2: Change of real-time LMPs due to bad data

the prices associated with each region change, sometimes quite significantly.

Before characterizing impacts of bad meter data on LMP, we need to construct appropriate models for bad data. To this end, we propose three increasingly more powerful bad data models based on the dependencies on real-time system measurements: state independent bad data, partially adaptive bad data, and fully adaptive bad data.

In studying the worst case performance, we adopt a widely used approach that casts the problem as one involving an adversary whose goal is to make the system performance as poor as possible. By giving the adversary more information about the network state and endowing him with the ability to change data, we are able to capture the worst case performance, sometimes exactly and sometimes as bounds on performance. The approach of finding the worst data is therefore equivalent to finding the optimal strategy of an attacker who tries to perturb the real-time LMP and avoid being detected at the same time. To this end, we are able to formulate the problem of finding the optimal attack as certain convex optimizations.

Thus, when we discuss “attacks” of an “adversary”, we mean to use the notion of adversary as a proxy to construct worst data. In practice, however, it is not impossible that worst data obtained in this paper are results of a physically launched attack by someone who has the necessary system parameters and the ability to modify meter data before they reach the control center.

Finally, we perform simulation studies using several benchmark networks: IEEE-14 and IEEE-118 networks. We observe that bad data independent of the system state seems to have

limited impact on real-time LMPs, and greater price perturbation can be achieved by state dependent bad data. The results also demonstrate that the real-time LMPs are subject to much larger perturbation if bad topology data are present in addition to bad meter data. While substantial price changes can be realized for small networks by the worst meter data, as the size of network grows while the measurement redundancy rate remains the same, the influence of worst meter data on LMP is reduced. However, larger system actually gives more possibilities for the bad topology data to perturb the real-time LMP more significantly.

Our simulation results also show a degree of robustness provided by the *nonlinear state estimator*. While there have been many studies on data injection attacks based on DC models, very few consider the fact that the control center typically employs the nonlinear WLS state estimator under the AC model. Our simulation shows that the effect of bad analog data on LMP is significantly mitigated by the nonlinear estimator whereas bad topology data coupled with bad analog data can have significant impacts on LMP.

B. Related Work

Effects of bad data on power system have been studied extensively in the past, see [3], [4], [5]. Finding the worst case bad data is naturally connected with the problem of malicious data. In this context, the results presented in this paper can be viewed as one of analyzing the impact of the worst (malicious) data attack.

In a seminal paper by Liu, Ning, and Reiter [6], the authors first illustrated the possibility that, by compromising enough number of meters, an adversary can perturb the state estimate arbitrarily in some subspace of the state space without being detected by any bad data detector. Such attacks are referred to as strong attacks. It was shown by Kosut *et al.* [7], [8] that the condition for the existence of such undetectable attacks is equivalent to the classical notion of network observability. The connection to network observability leads to a graph theoretic approach to characterizing the vulnerability of the power system by the so-called *security index*—the smallest set of attacked meters that will cause unobservability [8].

When the adversary can only inject malicious data from a small number of meters, strong attacks do not exist, and any injected malicious data can be detected with some probability. Such attacks are referred to as weak attacks [8]. In order to affect the system operation in some meaningful way, the adversary has to risk being detected by the control center. The impacts of weak attack on power system are not well understood because the detection of such bad data is probabilistic. Our results are perhaps the first to quantify such impacts. Most related research works focus on DC model and linear estimator while only a few have address the nonlinearity effect [9].

It is well recognized that bad data can also cause topology errors [10], [11], [12], and techniques have been developed to detect topology errors. For instance, the residue vector from state estimation was analyzed for topology error detection [11], [10], [13]. Monticelli [14] first introduced the idea of generalized state estimation where, roughly speaking, the

topology that fits the meter measurements best is chosen as the topology estimate. Abur *et al.* [15] and Mili *et al.* [16] extended the idea to various state estimation formulations. The impacts of topology errors on electricity market have not been reported in the literature, and this paper aims to bridge this gap.

The effect of data quality on real-time market was first considered in [17], [18]. In [18], the authors presented the financial risks induced by the data perturbation and proposed a heuristic technique for finding a case where price change happens. While there are similarities between this paper and [18], several significant differences exist: (i) This paper presents a worst case analysis. We focus on finding the worst case, not only a feasible case. (ii) This paper considers a more general class of bad data where bad data may depend dynamically on the actual system measurements whereas bad data considered in [18] are static. (iii) This paper considers a broader range of bad data that also include bad topology data, and our evaluations are based on the AC network model and the presence of nonlinear state estimator.

C. Organization and Notation

This paper is organized as follows. Section II briefly describes a model of real-time LMP and introduces its geometric characterization in the state space of the power system. This geometric characterization is the key in guiding our search for the worst case real-time price perturbation. Section III establishes the bad data models and summarizes state estimation and bad data detection procedures at the control center. In Section IV, we first use a simple example to show how the price can be affected by bad meter data. Then a metric of impact on real-time LMP caused by bad meter data is introduced. We then discuss the algorithms of finding worst case bad meter data vector in terms of real-time price perturbation under the three different bad data models. Section V considers the effect of bad topology data on real-time LMP. Finally, in Section VI, simulation results are presented based on IEEE-14 and IEEE-118 networks.

Notations used in this paper are standard. Vector $x = (x_1, \dots, x_n)$ is a column vector. We use the convention that, if x is a vector associated with some quantity of the system (e.g., system state), $\hat{x}$ is an *estimate* of x from real data. For reference, a list of global variables are given below.

a	vector added to meter data by adversary
c	vector of generation offers
d	vector of forecasted demands
$f, \hat{f}$	vector of branch flows and its real-time estimate
p^*	optimal day-ahead dispatch vector
r	measurement residue
s	transmission line connectivity measurements
w	measurement noise
$x, \hat{x}$	system state vector and its real-time estimate
z	vector of real-time measurements
$\mathcal{A}$	set of feasible perturbations on meter data

A	sensitivity matrix of branch flows with respect to power injections, also called PTDF (Power Transfer Distribution Factors)
$\mathcal{C}, \hat{\mathcal{C}}$	congestion pattern and its real-time estimate
$\mathcal{E}$	set of connected transmission lines between buses
$\mathcal{E}_\Delta$	set of lines that the adversary aims to remove
F	sensitivity matrix of branch flows with respect to state
$\mathcal{G}$	directed graph representing the system topology
H	measurement matrix of the DC model
K	Linear state estimation operator
$T^{\max}$	vector of branch flow limits
$\mathcal{V}$	set of buses
$\mathcal{X}$	state space
λ^*	locational marginal price (LMP) vector
$\hat{\lambda}$	real-time LMP vector
τ	threshold of bad data detector

II. STRUCTURES OF REAL-TIME LMP

In this section, we present first a model for the computation of real-time locational marginal price (LMP). While ISOs have somewhat different methods of computing real-time LMP, they share the same two-settlement architecture and similar ways of using real-time measurements. In the following, we will use a simplified ex-post real-time market model, adopted by PJM, ISO New England, and other ISOs [19], [20]. Our purpose is not to include all details; we aim to capture the essential features.

In real-time, in order to monitor and operate the system, the control center will calculate the estimated system conditions (including bus voltages, branch flows, generation, and demand) based on real-time measurements. We call a branch congested if the estimated flow is larger than or equal to the security limit. The congestion pattern is defined as the set of all congested lines, denoted as $\hat{\mathcal{C}}$. Notice that we use hat here since the congestion pattern is a function of state estimate. Details of state estimation and bad data detection are discussed in Section III-B.

One important usage of state estimation is calculating the real-time LMP. Given the estimated congestion pattern $\hat{\mathcal{C}}$, the following linear program is solved to find the incremental OPF dispatch and associated real-time LMP, $\hat{\lambda} = (\hat{\lambda}_i)$ [19]:

$$\begin{aligned}
 & \text{minimize} && \sum c_i^G \Delta p_i - \sum c_j^L \Delta d_j \\
 & \text{subjct to} && \sum \Delta p_i = \sum \Delta d_j \\
 & && \Delta p_i^{\min} \leq \Delta p_i \leq \Delta p_i^{\max} \\
 & && \Delta d_j^{\min} \leq \Delta d_j \leq \Delta d_j^{\max} \\
 & && \sum_i A_{ki} \Delta p_i - \sum_j A_{kj} \Delta d_j \leq 0, \text{ for all } k \in \hat{\mathcal{C}},
 \end{aligned} \tag{1}$$

where $\Delta d = (\Delta d_j)$ is the vector of incremental dispatchable load, $\Delta p = (\Delta p_i)$ the vector of incremental generation dispatch, $c^G = (c_i^G)$ and $c^L = (c_j^L)$ the corresponding real-time marginal cost of generations and dispatchable loads, $\Delta p_i^{\min}$ and $\Delta p_i^{\max}$ the lower and upper bounds for incremental dispatch, and A_{ki} the sensitivity of branch flow on branch k with respect to the power injection at bus i .

Suppose that we add a virtual demand $\tilde{d}_u$ at bus u . The corresponding Lagrange multiplier of the modified incremental

OPF with $\tilde{d}_u$ is given by

$$\begin{aligned}\mathcal{L} = & \sum_i c_i^G \Delta p_i - \sum_j c_j^L \Delta d_j + \eta(\sum_i \Delta p_i - \sum_j \Delta d_j - \tilde{d}_u) \\ & + \sum_i (\phi_i^+ (\Delta p_i^{\min} - \Delta p_i) + \phi_i^- (\Delta p_i \leq \Delta p_i^{\max})) \\ & + \sum_j (\psi_j^+ (\Delta d_j^{\min} - \Delta d_j) + \psi_j^- (\Delta d_j \leq \Delta d_j^{\max})) \\ & + \sum_{k \in \hat{\mathcal{C}}} \mu_k (\sum_i A_{ki} \Delta p_i - \sum_j A_{kj} \Delta d_j - A_{ku} \tilde{d}_u),\end{aligned}$$

where the scalars $\eta, \phi_i^+, \phi_i^-, \psi_j^+, \psi_j^-$, and μ_k are corresponding dual variables of the problem in (1).

The real-time LMP at bus u is defined as the overall cost increase when one unit of extra load is added at bus u , which is the derivative of the Lagrangian multiplier with respect to the virtual demand $\tilde{d}_u$ at $\tilde{d}_u = 0$, i.e.,

$$\hat{\lambda}_u = \left. \frac{\partial \mathcal{L}}{\partial \tilde{d}_u} \right|_{\tilde{d}_u=0} = \eta - \sum_{k \in \hat{\mathcal{C}}} A_{ku} \mu_k. \quad (2)$$

Notice that once the congestion pattern $\hat{\mathcal{C}}$ is determined, the whole incremental OPF problem (1) no longer depends on the measurement data, and thus neither do real-time LMPs.

Under the DC model, the power system state, x , is defined as the vector of voltage phases, except the phase on the reference bus. The power flow vector f is a function of the system state x ,

$$f = Fx, \quad (3)$$

where F is the sensitivity matrix of branch flows with respect to the system state.

Assume the system has $n + 1$ buses. Then, $x \in \mathcal{X} = [-\pi, \pi]^n$, where $\mathcal{X}$ represents the state space. Any system state corresponds to a unique point in $\mathcal{X}$. From (3), the branch flow f is determined by the system state x . Comparing the flows with the flow limits, we obtain the congestion pattern associated with this state. Hence, each point in the state space corresponds to a particular congestion pattern. The following theorem establishes the relationship between the state space and real-time price.

Theorem 1 (Price Partition of the State Space): The state space $\mathcal{X}$ is partitioned into a set of polytopes $\{\mathcal{X}_i\}$ where the interior of each $\mathcal{X}_i$ is associated with a unique congestion pattern $\mathcal{C}_i$ and a real-time LMP vector. Each boundary hyperplane of $\mathcal{X}_i$ is defined by a single transmission line.

Proof: For a particular congestion pattern $\mathcal{C}$ defined by a set of congested lines, the set of states that gives $\mathcal{C}$ is

$$\mathcal{X}_i \triangleq \{x : F_{i \cdot} x \geq T_i^{\max} \forall i \in \mathcal{C}, F_{j \cdot} x < T_j^{\max} \forall j \notin \mathcal{C}\},$$

where F is the linear matrix factor between state and line flows (see 3), $F_{i \cdot}$ the i th row of F , and $T_j^{\max}$ the flow limit on branch j .

Since $\mathcal{X}_i$ is defined by the intersection of a set of half spaces, it is a polytope. From previous discussion, each congestion pattern is associated with a particular real-time LMP vector λ . All states with the same congestion pattern share the same real-time LMP. Hence each convex polytope $\mathcal{X}_i$ in $\mathcal{X}$ corresponds to a real-time LMP vector. ■

Theorem 1 characterizes succinctly the relationship between the system state and LMP. As illustrated in Fig. 2(a), if bad

data are to alter the LMP in real-time, the size of the bad data has to be sufficiently large so that the state estimate at the control center is moved to a different price region from the true system state.

On the other hand, if some lines are erroneously removed from or added to the correct topology, as illustrated in Fig. 2(b), it affects the LMP calculation in two ways. First, the price partition of the state space changes due to the errors in topology information. Secondly, the shift matrix A in (1), which is a function of topology, changes thereby altering prices attached to each price region.

III. DATA MODEL AND STATE ESTIMATION

A. Bad Data Model

1) *Meter data:* In order to monitor the system, various meter measurements are collected in real time, such as power injections, branch flows, voltage magnitudes, and phasors, denoted by a vector z . If there exists bad data a among the measurements, the measurement with bad data, denoted by z_a , can then be expressed as a function of the system states x ,

$$z_a = z + a = h(x) + w + a, \quad a \in \mathcal{A}, \quad (4)$$

where w represents the random measurement noise.

We make a distinction here between the measurement noise and bad data; the former accounts for random noise independently distributed across all meters whereas the latter represents the perturbation caused by bad or malicious data. We assume no specific pattern for bad data except that they do not happen everywhere. We assume that bad data can only happen in a subset of the measurements, $\mathcal{S}$. If the cardinality of $\mathcal{S}$ is k , the feasible set of bad data a is a k -dimensional subspace, denoted as $\mathcal{A} = \{a : a_i = 0 \text{ for all } i \notin \mathcal{S}\}$.

We will consider three bad data models with increasing power of affecting state estimates.

M1. State independent bad data: This type of bad data is independent of real-time measurements. Such bad data may be the replacement of missing measurements.

M2. Partially adaptive bad data: This type of bad data may arise from the so-called man in the middle (MiM) attack where an adversary intercepts the meter data and alter the data based on what he has observed. Such bad data can adapt to the system operating state.

M3. Fully adaptive bad data: This is the most powerful type of bad data, constructed based on the actual measurement $z = h(x) + w$.

Note that M3 is in general not realistic. Our purpose of considering this model is to use it as a conservative proxy to obtain performance bounds for the impact of worst case data.

We assume herein a DC model in which the measurement function $h(\cdot)$ in (4) is linear. Specifically,

$$z_a = Hx + w + a, \quad a \in \mathcal{A}, \quad (5)$$

where H is the measurement matrix. Such a DC model, while widely used in the literature, may only be a crude approximation of the real power system. By making such a simplifying assumption and acknowledging its weaknesses, we hope to obtain tractable solutions in searching for worst

case scenarios. It is important to note that, although the worst case scenarios are derived from the DC model, we carry out simulations using the actual nonlinear system model.

2) *Topology data*: Topology data are represented by a binary vector $s \in \{0, 1\}^l$, where each entry of s represents the state of a line breaker (0 for open and 1 for closed). The bad topology data is modeled as

$$s_b = s + b \pmod{2}, \quad b \in \mathcal{B}, \quad (6)$$

where $\mathcal{B} \subset \{0, 1\}^l$ is the set of possible bad data. When bad data are present, the topology processor will generate the topology estimate corresponding to s_b , and this incorrect topology estimate will be passed to the following operations unless detected by the bad data detector.

B. State Estimation

We assume that the control center employs the standard weighted least squares (WLS) state estimator

$$\hat{x} = \arg \min_x (z - h(x))^T R^{-1} (x - h(x)), \quad (7)$$

where R is the covariance matrix of measurement noise w . Under the DC model, the WLS estimator is given by

$$\hat{x} = Kz, \quad K \triangleq (H^T R^{-1} H)^{-1} H^T R^{-1}. \quad (8)$$

If the noise w is Gaussian, the WLS estimator is also the maximum likelihood estimate (MLE) of state x . By the invariant property of MLE, from (3), the maximum likelihood estimate of the branch flows is calculated as

$$\hat{f} = F\hat{x} = FKz. \quad (9)$$

The estimated congestion pattern used in real-time LMP calculation (1) consists of all the estimated branch flows which are larger than or equal to the branch flow limits, *i.e.*,

$$\hat{\mathcal{C}} = \{j : \hat{f}_j \geq T_j^{\max}\}, \quad (10)$$

where $T_j^{\max}$ is the flow limit on branch j .

In the presence of bad meter data a , the meter measurements collected by control center is actually $z_a = Hx + w + a$. By using z_a , the WLS state estimate is

$$\hat{x}_a = Kz_a = \hat{x}^* + Ka, \quad (11)$$

where $\hat{x}^* = Kz$ is the “correct” state estimate without the presence of the bad data (*i.e.*, $a = 0$).

(11) shows that the effect of bad data on state estimation is linear. However, because a is confined in a k -dimensional subspace $\mathcal{A}$, the perturbation on the actual system state is limited to a certain direction.

When bad data exist both in meter and topology data, the control center uses a wrong measurement matrix $\bar{H}$, corresponding to the altered topology data, and the altered meter data z_a . Then, the WLS state estimate becomes

$$\hat{x}_a = \bar{K}z_a = \bar{K}z + \bar{K}a, \quad (12)$$

where $\bar{K} \triangleq (\bar{H}^T R^{-1} \bar{H})^{-1} \bar{H}^T R^{-1}$. Note that unlike the linear effect of bad meter data, bad topology data affects the state estimate by altering the measurement matrix H to $\bar{H}$.

C. Bad Data Detection

The control center uses bad data detection to minimize the impact of bad data. Here, we assume a standard bad data detection used in practice, the $J(\hat{x})$ -detector in [4]. In particular, the $J(\hat{x})$ -detector performs the test on the residue error, $r \triangleq z - H\hat{x}$, based on the state estimate $\hat{x}$. From the WLS state estimate (8), we have

$$r = (I - H(H^T R^{-1} H)^{-1} H^T R^{-1}) z = Uz. \quad (13)$$

The $J(\hat{x})$ -detector is a threshold detector defined by

$$r^T R^{-1} r = z^T W z \begin{array}{c} \text{bad data} \\ \geq \\ \text{good data} \end{array} \tau,$$

where τ is the threshold calculated from a prescribed false alarm probability. When the measurement data fail to pass the bad data test, the control center declares the existence of bad data and takes corresponding actions to identify and remove the bad data.

In this paper, we are interested in those cases when bad data are present while the $J(\hat{x})$ -detector fails to detect them.

IV. IMPACT OF BAD DATA ON LMP

In this section, we examine the impact of bad data on LMP, assuming that the topology estimate of the network is correct.

A. Relative Price Perturbation

In order to quantify the effect of bad data on real-time price, we need to first define the metric to measure the effect. We define the *relative price perturbation* (RPP) as the expected percentage price perturbation caused by bad data. Given that LMP varies at different buses, RPP also varies at different locations.

Let z_a be the data received at the control center and $\lambda_i(z_a)$ the LMP at bus i . The RPP at bus i is a function of bad data a , given by

$$\text{RPP}_i(a) = \mathbb{E} \left(\left| \frac{\lambda_i(z_a) - \lambda_i(z)}{\lambda_i(z)} \right| \right), \quad (14)$$

where the expectation is over random measurements

To measure the system-wide price perturbation, we define the *average relative price perturbation* (ARPP) by

$$\text{ARPP}(a) = \frac{1}{n+1} \sum_i \text{RPP}_i(a), \quad (15)$$

where $n+1$ is the number of buses in the system.

B. Worst RPP under State Independent Bad Data Model

First, we consider the state independent bad data model (M1) given in Section III-A. In this model, the bad data are independent of real-time measurements.

In constructing the state independent worst data, it is useful to incorporate prior information about the state. To this end, we assume that system state follows a Gaussian distribution with mean x_0 , covariance matrix Σ_x . Typically, we choose x_0 as the day-ahead dispatch since the nominal system state in real-time varies around its day-ahead projection.

In the presence of bad data a , the expected state estimate and branch flow estimate on branch i are given by

$$\mathbb{E}[\hat{x}] = x_0 + Ka. \quad (16)$$

$$\mathbb{E}[f_i] = F_i \mathbb{E}[\hat{x}] = F_i x_0 + F_i K, \quad (17)$$

where F_i is the corresponding row of branch i in F .

Our strategy is to make this expected state estimate into the region with the largest price perturbation among all the possible regions, $\hat{C}^*$. From (10), this means making all the expected branch flows satisfy the boundary condition of $\hat{C}^*$ as follows,

$$\begin{aligned} \mathbb{E}[f_i] &\geq T_i^{\max} & \text{for } i \in \hat{C}^* \\ \mathbb{E}[f_i] &\leq T_j^{\max} & \text{for } j \notin \hat{C}^*. \end{aligned} \quad (18)$$

However, due to the uncertainty (from both system state x and measurement noise w), the actual estimated state after attack, $\hat{x}$, may be different from $\mathbb{E}[\hat{x}]$. Therefore, we want to make $\mathbb{E}[\hat{x}]$ at the “center” of the desired price region, *i.e.*, maximizing the shortest distance from $\mathbb{E}[\hat{x}]$ to the boundaries of the polytope price regions while still holding the boundary constraints. The shortest distance can be calculated as

$$\beta = \min\{\tilde{\beta} : |\mathbb{E}[f_i] - T^{\max}| \geq \tilde{\beta} \text{ for all } i\}. \quad (19)$$

However, the existence of bad data detector prevents the bad data vector a from being arbitrarily large. According to (13), the weighted squared residue with a is

$$r^T R^{-1} r = (w + a)^T W (w + a). \quad (20)$$

Heuristically, since w has zero mean, the term $a^T W a$ can be used to quantify the effect of data perturbation on estimation residue. Then we use $a^T W a \leq \epsilon$ to control the detection probability in the following optimization.

Therefore, for a specific congestion pattern $\hat{C}$, the adversary will solve the following optimization problem to move the state estimate to the “center” of the price region $\hat{C}$ and keeping the detection probability low.

$$\begin{aligned} \max_{a \in \mathcal{A}, \tilde{\beta} \geq 0} & \quad \tilde{\beta} \\ \text{subject to} & \quad \mathbb{E}[f_i] - \tilde{\beta} \geq T_i^{\max}, i \in \hat{C} \\ & \quad \mathbb{E}[f_i] + \tilde{\beta} < T_j^{\max}, j \notin \hat{C} \\ & \quad a^T W a \leq \epsilon, \end{aligned} \quad (21)$$

which is a convex program that can be solved easily in practice. We call a region $\hat{C}$ feasible if it makes problem (21) feasible.

The set of all the feasible congestion patterns is denoted as Γ . In order to find the “worst” feasible region with largest price perturbation, we need to screen all the possible congestion patterns.

If we use RPP as the index with bus i as the target, the worst region is chosen as

$$\hat{C}^* = \arg \max_{\hat{C} \in \Gamma} |\tilde{\lambda}_i - \lambda_i(\hat{C})|, \quad (22)$$

where $\tilde{\lambda}_i$ is the LMP at bus i if the x_0 is the system state.

If we use ARPP as the index, the worst region is chosen as

$$\hat{C}^* = \arg \max_{\hat{C} \in \Gamma^c} \sum_i \left| \frac{\tilde{\lambda}_i - \lambda_i(\hat{C})}{\tilde{\lambda}_i} \right|. \quad (23)$$

Therefore, the worst case constant bad data vector is the solution to optimization problem (21) by setting the congestion pattern as $\hat{C}^*$.

C. Worst RPP under Partially Adaptive Bad Data

For bad data model M2, only part of the measurement values in real-time are known to the adversary, denoted as z_0 . The adversary has to first make an estimation of the system state from the observation and prior distribution, then make the attack decision based on the estimation result.

Without the presence of bad data vector, *i.e.*, $a = 0$, the system equation (5) gives

$$z_0 = H_0 x + w_0, \quad (24)$$

where H_0 is the rows of H corresponding to the observed measurements and w_0 the corresponding part in the measurement noise w .

The minimum mean square error (MMSE) estimate of x given z_0 is given by the conditional mean

$$\mathbb{E}(x|z_0) = x_0 + \Sigma_x H_0^T (H_0 \Sigma_x H_0^T)^{-1} (z_0 - H_0 x_0). \quad (25)$$

Then, the flow estimate on branch i after attack is

$$\mathbb{E}[f_i|z_0] = F_i \mathbb{E}[\hat{x}|z_0]. \quad (26)$$

Still, we want to move the estimation of state to the “center”. On the other hand, the expected measurement value $\mathbb{E}[z_a|z_0] = H \mathbb{E}[\hat{z}|z_0] + a$. We need a pre-designed parameter ϵ to control the detection probability. Therefore, the solution to the following optimization problem is the best attack given congestion pattern $\mathcal{A}$

$$\begin{aligned} \max_{a \in \mathcal{A}, \tilde{\beta} \geq 0} & \quad \tilde{\beta} \\ \text{subject to} & \quad \mathbb{E}[f_i|z_0] - \tilde{\beta} \geq T_i^{\max}, i \in \hat{C} \\ & \quad \mathbb{E}[f_i|z_0] + \tilde{\beta} < T_j^{\max}, j \notin \hat{C} \\ & \quad (H \mathbb{E}[z_a|z_0]^T) W (H \mathbb{E}[z_a|z_0]) \leq \epsilon. \end{aligned} \quad (27)$$

This problem is also a convex optimization problem, which can be easily solved. Among all the $\hat{C}$'s which make the above problem feasible, we choose the one with the largest price perturbation, denoted as $\hat{C}^*$. The solution to problem (27) with $\hat{C}^*$ as the congestion pattern is the worst bad data vector.

D. Worst RPP under Fully Adaptive Bad Data

Finally, we consider the bad data model M3, in which the whole set of measurements z is known to the adversary. The worst bad data vector depends on the value of z . Different from the previous two models, with bad data vector a , the estimated state is deterministic without uncertainty. In particular

$$\hat{x} = Kz + Ka. \quad (28)$$

And the estimated flow on branch i after attack is also deterministic

$$\hat{f}_i = F_i \hat{x} = F_i Kz + F_i Ka. \quad (29)$$

Similar to the previous two models, congestion pattern is called available if there exists some bad data vector a to make the following conditions satisfied:

$$\begin{aligned} \hat{f}_i &\geq T_i^{\max}, i \in \hat{\mathcal{C}} \\ \hat{f}_i &< T_i^{\max}, i \notin \hat{\mathcal{C}} \\ (z+a)^T W(z+a) &\leq \tau, \quad a \in \mathcal{A}. \end{aligned} \quad (30)$$

Among all the feasible congestion patterns, we choose the one with the largest price perturbation, $\hat{\mathcal{C}}^*$. Any bad data vector a satisfies condition (30) can serve as the worst fully adaptive bad data.

V. BAD TOPOLOGY DATA ON LMP

So far, we have considered bad data in the analog measurements. In this section, we include the bad *topology* data, and describe another bad data model.

We represent the network topology by a directed graph $\mathcal{G} = (\mathcal{V}, \mathcal{E})$ where each $i \in \mathcal{V}$ denotes a bus and each $(i, j) \in \mathcal{E}$ denotes a *connected* transmission line. For each physical transmission line (e.g., a physical line between i and j), we assign an arbitrary direction (e.g., (i, j)) for the line, and (i, j) is in $\mathcal{E}$ if and only if bus i and bus j are connected in the power network.

Bad data may appear in both analog measurements and digital (e.g., breaker status) data, as described in Section III-A:

$$\begin{aligned} z_a &= z + a = (Hx + w) + a, \quad a \in \mathcal{A}, \\ s_b &= s + b \pmod{2}, \quad b \in \mathcal{B}. \end{aligned} \quad (31)$$

As in Section IV, we employ the adversary model to describe the worst case. The adversary alters s to s_b by adding b from the set of feasible attack vectors $\mathcal{B} \subset \{0, 1\}^l$ such that the topology processor produces the “target” topology $\bar{\mathcal{G}}$ as the topology estimate. In addition, the adversary modifies z by adding $a \in \mathcal{A}$ such that z_a looks consistent with $\bar{\mathcal{G}}$.

In this section, we focus on the worst case when the adversary is able to alter the network topology without changing the state estimate*. We also require that such bad data are generated by an adversary causing undetectable topology change, i.e., the bad data escape the system bad data detection. For the worst case analysis, we will maximize the LMP perturbation among the attacks within this specific class. Even though this approach is suboptimal, the simulation results in Section VI demonstrate that the resulting LMP perturbation is much greater than the worst case of the bad meter data.

Suppose the adversary wants to mislead the control center with the target topology $\bar{\mathcal{G}} = (\mathcal{V}, \bar{\mathcal{E}})$, a topology obtained by removing a set of transmission lines $\mathcal{E}_\Delta$ in $\mathcal{G}$ (i.e., $\bar{\mathcal{E}} = \mathcal{E} \setminus \mathcal{E}_\Delta$). We assume that the system with $\bar{\mathcal{G}}$ is observable: i.e., the measurement matrix $\bar{H}$ corresponding to $\bar{\mathcal{G}}$ has full column rank[†].

Suppose that the adversary changes the breaker status such that the target topology $\bar{\mathcal{G}} = (\mathcal{V}, \bar{\mathcal{E}})$ is observed at the control

*In general, the adversary can design the worst data to affect both the state estimate and network topology. It is, however, much more difficult to make such attack undetectable.

[†]Without observability, the system may not proceed to state estimation and real-time pricing. Hence, for the adversary to affect pricing, the system with the target topology has to be observable




Fig. 3: Hx and $\bar{H}x$: Each row is marked by the corresponding meter (i for injection at i and (i, j) for flow from i to j).

center. Simultaneously, if the adversary introduces bad data $a = \bar{H}x - Hx$, then the meter data received at the control center become

$$z_a = Hx + a + w = \bar{H}x + w, \quad (32)$$

which means that the data received at the control center are completely consistent with the model generated from $\bar{\mathcal{G}}$. Thus, any bad data detector will not be effective.

It is of course not obvious how to produce the bad data a , especially when the adversary can only modify a limited number of measurements, and it may not have access to the entire state vector x . Fortunately, it turns out that a can be generated by observing only a few entries in z without requiring global information (such as the state vector x) [21].

A key observation is that Hx and $\bar{H}x$ differ only in a few entries corresponding to the modified topology (lines in $\mathcal{E}_\Delta$) as illustrated in Fig. 3. Consider first the noiseless case. Let z_{ij} denote the entry of z corresponding to the flow measurement from i to j . As hinted from Fig. 3, it can be easily seen that $\bar{H}x - Hx$ has the following sparse structure [21]:

$$\bar{H}x - Hx = - \sum_{(i,j) \in \mathcal{E}_\Delta} \alpha_{ij} m_{(i,j)}, \quad (33)$$

where $\alpha_{ij} \in \mathbb{R}$ denotes the line flow from i to j when (i, j) is connected and the system state is x , and $m_{(i,j)}$ is the column of the measurement-to-branch incidence matrix, that corresponds to (i, j) : i.e., $m_{(i,j)}$ is an m -dimensional vector with 1 at the entries corresponding to the flow from i to j and the injection at i , and -1 at the entries corresponding to the flow from j to i and the injection at j , and 0 at all other entries. Absence of noise implies that $z_{ij} = \alpha_{ij}$, which leads to

$$\bar{H}x - Hx = - \sum_{(i,j) \in \mathcal{E}_\Delta} z_{ij} m_{(i,j)}. \quad (34)$$




Fig. 4: This figure describes how the attack alters the local measurements around the line (i, j) in $\mathcal{E}_\Delta$.

With (34) in mind, one can see that setting $a = \bar{H}x - Hx$ and adding a to z is equivalent to the following simple procedure: as described in Fig. 4, for each (i, j) in $\mathcal{E}_\Delta$,

- 1) Subtract z_{ij} and z_{ji} from z_i and z_j respectively.
- 2) Set z_{ij} and z_{ji} to be 0.

where z_i is the entry of z corresponding to the injection measurement at bus i .

When measurement noise is present (i.e., $z = Hx + w$), the idea of the attack is still the same: to make a approximate $\bar{H}x - Hx$ so that z_a is close to $\bar{H}x + w$. Since $z_{ij} = \alpha_{ij} + w_{ij}$, z_{ij} is an unbiased estimate of α_{ij} for each $(i, j) \in \mathcal{E}_\Delta$, and this implies that $-\sum_{(i,j) \in \mathcal{E}_\Delta} z_{ij} m_{(i,j)}$ is an unbiased estimate of $-\sum_{(i,j) \in \mathcal{E}_\Delta} \alpha_{ij} m_{(i,j)} = \bar{H}x - Hx$. Hence, we set a to be $-\sum_{(i,j) \in \mathcal{E}_\Delta} z_{ij} m_{(i,j)}$, the same as in the noiseless setting, and the attack is executed by the same steps as above.

For launching this attack to modify the topology estimate from $\mathcal{G}$ to $\bar{\mathcal{G}}$, the adversary should be able to (i) set b such that the topology processor produces $\bar{\mathcal{G}}$ instead of $\mathcal{G}$ and (ii) observe and modify z_{ij} , z_{ji} , z_i , and z_j for all $(i, j) \in \mathcal{E}_\Delta$. The attack is feasible if and only if $\mathcal{A}$ and $\mathcal{B}$ contain the corresponding attack vectors.

To find the worst case LMP perturbation due to undetectable, state-preserving attacks, let $\mathcal{F}$ denote the set of feasible $\bar{\mathcal{G}}$ s, for which the attack can be launched with $\mathcal{A}$ and $\mathcal{B}$. Among the feasible targets in $\mathcal{F}$, we consider the best target topology that results in the maximum perturbation in real-time LMPs. If RPP is used with bus i , the best target is chosen as

$$\bar{\mathcal{G}}^*[z] = \arg \max_{\bar{\mathcal{G}} \in \mathcal{F}} |\lambda_i(z; \bar{\mathcal{G}}) - \lambda_i(z; \mathcal{G})|, \quad (35)$$

where $\lambda_i(z; \bar{\mathcal{G}})$ denotes the real-time LMP at bus i when the attack with the target $\bar{\mathcal{G}}$ is launched on z , and $\lambda_i(z; \mathcal{G})$ is the real-time LMP under no attack. On the other hand, if ARPP is used, the best target is chosen as

$$\bar{\mathcal{G}}^*[z] = \arg \max_{\bar{\mathcal{G}} \in \mathcal{F}} \sum_i \left| \frac{\lambda_i(z; \bar{\mathcal{G}}) - \lambda_i(z; \mathcal{G})}{\lambda_i(z; \mathcal{G})} \right|. \quad (36)$$

For both RPP and ARPP, the bad data in the worst case are the attack vectors for the target $\bar{\mathcal{G}}^*[z]$.

VI. NUMERICAL RESULTS

In this section, we demonstrate the impact of bad data on real-time LMPs with the numerical simulations on IEEE-14 and IEEE-118 systems. We conducted simulations in two different settings: the linear model with the DC state estimator and the nonlinear model with the AC state estimator. The former is usually employed in the literature for the ease of

TABLE I: Adversary-controlled measurements

	Bus injection	Line flows (both directions) and line breaker states
IEEE-14	2, 5, 7, 9	(2, 5), (7, 9)
IEEE-118	4, 5, 51, 52, 88, 89	(4, 5), (51, 52), (88, 89)

analysis whereas the latter represents the practical state estimator used in the real-world power system. In all simulations, the meter measurements consist of power injections at all buses and power flows (both directions) at all branches.

A. Linear model with DC state estimation

We first present the simulation results for the linear model with the DC state estimator. We modeled bus voltage magnitudes and phases as Gaussian random variables with the means equal to the day-ahead dispatched values and small standard deviations. In each Monte Carlo run, we generated a state realization from the statistical model, and the meter measurements were created by the DC model with Gaussian measurement noise. Once the measurements were created, bad data were added in the manners discussed in Section IV and Section V. With the corrupt measurements, the control center executed the DC state estimation and the bad data test with the false alarm constraint 0.1. If the data passed the bad data test, real-time LMPs were evaluated based on the state estimation results.

For IEEE-14 and IEEE-118 system, the network parameters[‡] are available in [22]. Table I contains the list of measurements to which the adversary was assumed to be able to add bad data. In the partially adaptive bad data case, the adversary was assumed to observe measurements from a half of meters.


Fig. 5 and Fig. 6 are the plots of RPPs and ARPPs[§] versus detection probabilities of bad data. They show that even when bad data were detected with low probability, RPPs and ARPPs were large, especially for the fully adaptive bad meter data and the bad topology data.

Comparing RPPs and ARPPs of the three bad meter data models, we observe that the adversary may significantly improve the perturbation amount by exploiting partial or all real-time meter data. It is worthy to point out that bad topology


[‡] In addition to the network parameters given in [22], we used the following line limit and real-time offer parameters. In the IEEE-14 simulation, the generators at the buses 1, 2, 3, 6, and 8 had capacities 330, 140, 100, 100, and 100 MW and the real-time offers 15, 31, 30, 10, and 20 \$/MW. Lines (2, 3), (4, 5), and (6, 11) had line capacities 50, 50, and 20 MW, and other lines had no line limit. In the IEEE-118 simulation, the generators had generation costs arbitrarily selected from {20, 25, 30, 35, 40 \$/MW} and generation capacities arbitrarily selected from {200, 250, 300, 350, 400 MW}. Total 16 lines had the line capacities arbitrarily selected from {70, 90, 110 MW}, and other lines had no line limit.

[§] For RPPs and ARPPs in the bad topology data cases, we took the average over RPPs and ARPPs that are less than 200% to exclude the cases of price spikes, in which drastic changes occur in real-time LMPs. With the price spikes included, RPPs and ARPPs for the bad topology data become even larger than what we present here.

In addition, the detection probabilities for the fully adaptive bad meter data and the bad topology data cases were less than 0.1 in all the simulations. In the figures, we draw RPPs and ARPPs of those cases as horizontal lines so that we can compare them with other cases.




(a) IEEE-14: RPP for bus 14




(b) IEEE-118: RPP for bus 7

Fig. 5: Linear model: RPP vs detection prob.



(a) IEEE-14



(b) IEEE-118: ARPP of the worst topology data is 59.8%.


Fig. 6: Linear model: ARPP vs detection prob.

data result in much greater price perturbation than bad meter data.


Recall the discussion in Section II that bad topology data and bad meter data employ different price-perturbing mechanisms: bad topology data perturb real-time LMPs by restructuring the price regions (without perturbing the state estimate) whereas bad meter data perturb real-time LMPs by moving the state estimate to a different price region (without changing the price regions). Therefore, the observation implies that restructuring the price regions has much greater impact on real-time LMPs than merely perturbing the state estimate.

B. Nonlinear model with AC state estimation

The simulations with the nonlinear model intend to investigate the vulnerability of the real-world power system to the



(a) IEEE-14: RPP for bus 14. RPP of the worst topology data case is 23.9%.



(b) IEEE-118: RPP for bus 7. RPP of the worst topology data case is 30.0%.

Fig. 7: Nonlinear model: RPP vs detection prob.

worst adversarial act, designed based on the linear model. The simulations were conducted with IEEE-14 and IEEE-118 systems in the same manner as the linear case except that we employed the nonlinear model and the AC state estimation.

Fig. 7 and Fig. 8 are the plots of RPPs and ARPPs versus detection probabilities. Compared to the linear case results, RPPs and ARPPs of bad meter data were much lower whereas RPPs and ARPPs of bad topology data were still significant. Recall that the bad meter data were designed based on the linear model to move the state estimate to the worst price region. Small price perturbations by bad meter data imply that the state estimate of the AC state estimation was not moved as the adversary intended. On the other hand, large price perturbations by bad topology data imply that the real-time LMPs in the real-world power systems may experience large errors under the presence of maliciously designed, bad topology data.

VII. CONCLUSION

We report in this paper a study on impacts of the worst data on the real-time market operation. A key result of this paper is the geometric characterization of real-time LMPs given in Theorem 1. This result provides the insights into the relation between data and LMPs and serves as the basis of characterizing impacts of the worst data.

Our investigation on the effect of the worst data includes bad data scenarios that arise from both analog meter measurements and digital breaker state data. To this end, we have developed a systematic approach to finding the worst data by casting the problem as one involving an adversary injecting malicious




Fig. 8: Nonlinear model: ARPP vs detection prob.

data. While such an approach often gives overly conservative analysis, it does provide important assurance when the impacts of the worst data are deemed acceptable. On the other hand, because we use adversary attacks as a way to study the worst data, our results have direct implications when cyber-security of smart grid is considered.

Although our findings are obtained from academic benchmarks involving relatively small size networks, we believe that the general trend that characterizes the effects of bad data is likely to persist in practical networks of much larger size. In particular, as the network size increases and the number of simultaneous appearance of bad data is limited, the effects of the worst meter data on LMP decrease whereas the effects of the worst topology data stay nonnegligible regardless of the network size. This observation suggests that the bad topology data are potentially more detrimental to the real-time market operation than the bad meter data.

REFERENCES

- [1] E. Litvinov, T. Zheng, G. Rosenwald, and P. Shamsollahi, "Marginal loss modeling in lmp calculation," *IEEE Transaction on Power System*, vol. 19, no. 2, 2004.
- [2] T. Zheng and E. Litvinov, "Ex post pricing in the co-optimized energy and reserve market," *IEEE Transaction on Power System*, vol. 21, no. 4, 2006.
- [3] A. Abur and A. G. Expósito, *Power System State Estimation: Theory and Implementation*. CRC, 2000.
- [4] E. Handschin, F. C. Schweppe, J. Kohlas, and A. Fiechter, "Bad data analysis for power system state estimation," *IEEE Trans. Power Apparatus and Systems*, vol. PAS-94, no. 2, pp. 329–337, Mar/Apr 1975.
- [5] F. C. Schweppe, J. Wildes, and D. P. Rom, "Power system static state estimation, Parts I, II, III," *IEEE Tran. on Power Appar. & Syst.*, vol. PAS-89, pp. 120–135, 1970.

- [6] Y. Liu, P. Ning, and M. K. Reiter, "False data injection attacks against state estimation in electric power grids," in *ACM Conference on Computer and Communications Security*, 2009, pp. 21–32.
- [7] O. Kosut, L. Jia, R. J. Thomas, and L. Tong, "Malicious data attacks on smart grid state estimation: attack strategies and countermeasures," in *Proc. IEEE 2010 SmartGridComm*, Gaithersburg, MD, USA, Oct 2010.
- [8] —, "Malicious data attacks on the smart grid," *IEEE Transactions on Smart Grid*, vol. 2, no. 4, pp. 645–658, dec. 2011.
- [9] L. Jia, R. J. Thomas, and L. Tong, "On the nonlinearity effects on malicious data attack on power system," in *2012 Power and Energy Society general meeting*, July 2012.
- [10] F. F. Wu and W. E. Liu, "Detection of topology errors by state estimation," *IEEE Trans. Power Systems*, vol. 4, no. 1, pp. 176–183, Feb 1989.
- [11] K. Clements and P. Davis, "Detection and identification of topology errors in electric power systems," *IEEE Transactions on Power Systems*, vol. 3, no. 4, pp. 1748–1753, nov 1988.
- [12] A. Monticelli, *State Estimation in Electric Power Systems: A Generalized Approach (Power Electronics and Power Systems)*. Monticelli, 1999.
- [13] I. Costa and J. Leao, "Identification of topology errors in power system state estimation," *IEEE Transactions on Power Systems*, vol. 8, no. 4, pp. 1531–1538, nov 1993.
- [14] A. Monticelli, "Modeling circuit breakers in weighted least squares state estimation," *IEEE Transactions on Power Systems*, vol. 8, no. 3, pp. 1143–1149, aug 1993.
- [15] A. Abur, H. Kim, and M. Celik, "Identifying the unknown circuit breaker statuses in power networks," *IEEE Transactions on Power Systems*, vol. 10, no. 4, pp. 2029–2037, nov. 1995.
- [16] L. Mili, G. Steeno, F. Dobraca, and D. French, "A robust estimation method for topology error identification," *IEEE Transactions on Power Systems*, vol. 14, no. 4, pp. 1469–1476, nov 1999.
- [17] R. J. Thomas, L. Tong, L. Jia, and O. E. Kosut, "Some economic impacts of bad and malicious data," in *PSerc 2010 Workshop*, vol. 1, Portland Maine, July 2010.
- [18] L. Xie, Y. Mo, and B. Sinopoli, "False data injection attacks in electricity markets," in *Proc. IEEE 2010 SmartGridComm*, Gaithersburg, MD, USA, Oct 2010.
- [19] A. L. Ott, "Experience with pjm market operation, system design, and implementation," *IEEE Trans. Power Systems*, vol. 18, no. 2, pp. 528–534, May 2003.
- [20] T. Zheng and E. Litvinov, "On ex post pricing in the the real-time electricity market," *IEEE Transaction on Power System*, vol. 26, no. 1, 2011.
- [21] J. Kim and L. Tong, "On Topology Attack of a Smart Grid," in *2013 IEEE PES Innovative Smart Grid Technologies (ISGT)*, Washington, DC, February 2013.
- [22] "Power Systems Test Case Archive." [Online]. Available: <http://www.ee.washington.edu/research/pstca/>